




MUNICIPAL CORPORATION OF DELHI  
Public Health Department, Keshav Puram Zone  
Office of the Deputy Health Officer  
A-1 Block, Keshavpuram, Delhi-110035  
E-mail : [dhokpz@gmail.com](mailto:dhokpz@gmail.com)




No. DHO/KPZ/2025/280


Dated: 5/6/25

**SCHOOL HEALTH CERTIFICATE**


1. Name of the School: GURU NANAK PUBLIC SCHOOL
2. Address of School: PUSHPANJALI ENCLAVE, PITAMPURA, DELHI-110034
3. No of Shifts: ONE Timing: 07:50 AM To 01:50 PM
4. No. of Students: Boys: 623 Girls: 479 Total: 1102
5. No. of Teaching Staff: Male: 04 Female: 56 Total: 60
6. Accommodation provided are as under:-

- ❖ Classrooms are well ventilated and well lighted.
- ❖ Floor areas in the classrooms are sufficient
- ❖ Classrooms are kept neat and clean.
- ❖ Building /Classrooms do not require white wash.
- ❖ Drinking water is wholesome.
- ❖ Latrine arrangement is sanitary.
- ❖ Number of Latrines and Urinals are sufficient.
- ❖ Separate toilet arrangements for Boys & Girls are available.
- ❖ Separate toilet arrangement for staff is available.
- ❖ The overall facilities are adequate.

  
Deputy Health Officer  
Keshav Puram Zone



**REMARKS: THIS CERTIFICATE IS VALID FOR ONE YEAR FROM THE DATE OF ISSUANCE.**

  
RAVINDER KAUR  
HOS  
GURU NANAK PUBLIC SCHOOL  
PUSHPANJALI ENCLAVE,  
PITAMPURA, NEW DELHI

  
MANAGER  
GURU NANAK PUBLIC S  
Pushpanjali Enclave, Pita  
Delhi-110034



**DELHI JAL BOARD ; ( GOVT. OF N.C.T. DELHI )  
QUALITY CONTROL LABORATORY,  
WATER TREATMENT PLANT HAIDERPUR,  
DELHI-110085.**



149  
28/3/24

(ISO Certified 9001:2015)

THE TEST REPORT IS FOR THIS PARTICULAR WATER SAMPLE ONLY

Water sample collected from DBO stored water in the premises of Guru Nanak Public School, Pushpanjali Enclave, Pitampura Delhi - 110034 vide challan no. 195 dated 11.03.2024.

S. No.	PARAMETERS	UNITS	Limit as per I.S.10500:2012		S1
			Acceptable	Permissible	
1.	Date of collection	--	---	---	20.03.2024
2.	Date of Analysis	--	---	---	21.03.2024
3.	Colour	C.U.	5	15	<1 C.U.
4.	Odour	--	Agreeable		Agreeable
5.	Turbidity	N.T.U	1.0	5.0	2.18
6.	p <sup>H</sup> value	--	6.5 to 8.5	N.R.	7.5
7.	Electrical Conductivity	umhos/cm	---	---	312.0
8.	Total Dissolved Solid	(mg/l)	500	2000	202.8
<b>CHEMICAL EXAMINATION</b>					
9.	Phenolphthalein Alkalinity	(mg/l)	---	---	Nil
10.	Total Alkalinity	(mg/l)	200	600	99.0
11.	Total Hardness	(mg/l)	200	600	135.0
12.	Calcium Hardness	(mg/l)	200	600	90.0
13.	Magnesium Hardness	(mg/l)	200	600	45.0
14.	Calcium as Ca	(mg/l)	75	200	36.0
15.	Magnesium as mg	(mg/l)	30	100	10.8
16.	Ammonia (as NH <sub>3</sub> -N)	(mg/l)	0.5	N.R.	ND
17.	Nitrite -Nitrogen (N)	(mg/l)	---	---	ND
18.	Nitrate (NO <sub>3</sub> )	(mg/l)	45	N.R.	2.19
19.	Sulphate (SO <sub>4</sub> )	(mg/l)	200	400	36.57
20.	Chloride (Cl)	(mg/l)	250	1000	14.0
21.	Iron (Fe)	(mg/l)	1.0	N.R.	0.04
22.	Fluorides (F)	(mg/l)	1.0	1.5	0.29
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	ND
24.	Residual Chlorine	(mg/l)	0.2	1.0	1.0
<b>BACTERIOLOGICAL EXAMINATION</b>					
25.	Coli form per 100 ml at 37°C	MPN/100 ml	0		0

Remarks: On the basis of above tested parameters, water sample (S1) confirms to drinking water specification I.S.10500:2012 and may be used for drinking purpose.

Asstt. Chemist  
21/3/24

Chemist/Bacteriologist

A.C.W.A. (HP- I)

C.W.A. (W&S)-II

RAVINDER KAUR  
HOS  
GURU NANAK PUBLIC SCHOOL  
PUSHPANJALI ENCLAVE,  
PITAMPURA, NEW DELHI

MANAGER  
GURU NANAK PUBLIC SCHOOL  
Pushpanjali Enclave, Pitam Pura,  
Delhi-110034